



ASTM E84 FIRE RATING STATEMENT

August 18, 2021

ARLON

Arlon Graphics declare that the graphic films we supply have been tested for Surface Burning Characteristics of Building Materials in accordance with the procedure outlined in ASTM E 84 (ANSI/UL 723; NFPA 225; and UBC 8-1).

This applies to the following products:

Product Name	Rating	Flame Spread	Smoke Developed
Digital Print Film (DPF)			
DPF 4200 Matte	A	15	10
DPF 4200 Canvas	A	20	25
DPF 4500GX	A	20	20
DPF 4600GLX/MLX	A	10	5
DPF 510GTR/MTR	A	20	115
DPF 6000XRP	A	10	0
DPF 8000 Ultra Tack	A	0	0
DPF 8200 High Tack	A	5	10
DPF 8200X High Tack	A	15	20
Overlaminates Series			
Series 3220	A	5	0
Series 3350	A	10	5
Series 3510	A	20	115

Arlon declares that no formula changes which have impact on tested properties have been made to any of the mentioned products during the period between testing and present. There is also no distinction between colors of tested film.

Prepared by:

Josh Nguyen
R&D Engineer
Arlon Graphics, LLC.



USA

a 200 Boysenberry Lane, Placentia, CA 92870
p 800 232 7161 / +1 714 985 6300
f +1 714 985 6305

EUROPE

a Dr. Lelykade 22B, 2583CM Den Haag, The Netherlands
p +31 70 354 4311
f +31 70 355 7721

CHINA

a No. 1989 Xinchang Road, Weifang, Shandong, 262400
p +86 0536 6226568