



BS EN 13501-1 FIRE RATING STATEMENT

ARLON

May 2025

Arlon Graphics declare that the graphic films we supply have been tested for Surface Burning Characteristics of Building Materials in accordance with the procedure outlined in BS EN 13823, BS EN ISO 11925-2.

This applies to the following products:

Product Name	Fire Behaviour	Smoke production	Flaming Droplets/particles
Digital Print Film (DPF)			
DPF V9500	C	s1	d0
DPF 4200 Matte	B	s1	d0
DPF 4200 Canvas	B	s1	d0
DPF 4300	C	s1	d0
DPF 4550G	B	s1	d0
DPF 4550GT	C	s1	d0
DPF 4550GTX	B	s1	d0
DPF 510UT	C	s1	d0
DPF 8000 Ultra Tack	C	s1	d0
DPF 8200 High Tack	C	s1	d0
DPF 8200X High Tack	C	s1	d0
DPF 5450X	B	s1	d0
Etched Glass Series			
Series 5400	B	s1	d0
Overlamine Series			
Series V3370S	B	s1	d0
Series 3220G	B	s1	d0
Series 3220M	B	s1	d0
Series 3210G	B	s1	d0
Series 3510M	C	s1	d0
Series 3450M	C	s1	d0

Arlon declares that no formula changes which have impact on tested properties have been made to any of the mentioned products during the period between testing and present. There is also no distinction between colors of tested film.

Prepared by:

Chi Chan

Chi Chan
Tech Service Engineer
Arlon Graphics, LLC.



USA

a 200 Boysenberry Lane, Placentia, CA 92870
p 800 232 7161 / +1 714 985 6300
f +1 714 985 6305

EUROPE

a Dr. Lelykade 22B, 2583CM Den Haag, The Netherlands
p +31 70 354 4311
f +31 70 355 7721

CHINA

a No. 1989 Xinchang Road, Weifang, Shandong, 262400
p +86 0536 6226568